REPORT DO	CUMENTATION PAGE	ΛEDI	~~		
Public reporting burden for this collection of information is estata needed, and completing and reviewing this collection of his burden to Department of Defense, Washington Headqua 302. Respondents should be aware that notwithstanding a ralid OMB control number. PLEASE DO NOT RETURN YO	imated to average 1 hour per response, including the time for information. Send comments regarding this burden estimate ters Services, Directorate for Information Operations and Re y other provision of law, no person shall be subject to any part IR FORM TO THE ABOVE ADDRESS.	or reviewing e or any oth eports (070 enalty for f	-SR-BL-TR-01- 0257	ig the ucing 202- urrentl	
I. REPORT DATE (DD-MM-YYYY)	2. REPORT TYPE		,		
02-18-2001	FINAL		3/1/20 4,_	,,,,,,,	
1. TITLE AND SUBTITLE			5a. CONTRACT NUMBER F49620-98-1-0185		
Research Instrumentation for Investigations	ting Advanced Magnetic Materials for A	Aircraft Power			
			5c. PROGRAM ELEMENT NUM	BER	
3. AUTHOR(S)			5d. PROJECT NUMBER		
			5e. TASK NUMBER		
Prof. Michael E. McHenry - Carnegie	Mellon University 412-268-2703,	Ļ			
			5f. WORK UNIT NUMBER	. ●!	
Principal Investigator FAX: 412-268-3113 PRINCIPAL PRIN			8. PERFORMING ORGANIZATIONUMBER	ON REPORT	
Prof. Michael E. McHenry Dept. of Mat. Sci. and Enc Carnegie Mellon University Pittsburgh, PA 15213-3890		ontracts			
Pr. Harold Weinstock		10. SPONSOR/MONITOR'S ACI	RONYM(S)		
Air Force Office of Scientific Research	NF Tel: 1-703-696-8572	,			
Directorate of Physics & Electronics 801 N. Randolph St., Room 732 Arlington VA 22203-1977 USA	Fax: 1-703-696-8481		11. SPONSOR/MONITOR'S REF NUMBER(S)	PORT .	
12. DISTRIBUTION / AVAILABILITY STATE	MENT				
APPECATE FOR PUPERCE DISTRIBUTION UNLIFERE		NOTICE OF TRANSM HAS BEEN REVIEWE	OF SCIENTIFIC RESEARCH (AFOSR) HTTAL DTIC. THIS TECHNICAL REPORT ED AND IS APPROVED FOR PUBLIC RELI HISTRIBUTION IS UNLIMITED.	EASE	
13. SUPPLEMENTARY NOTES		LAWATH 180-12. D	DITION TO WITH WITH THE PROPERTY OF THE PROPER		

4. ABSTRACT

A laser speckle interferometer has been purchased with DURIP funds (F49620-98-1-0185) and supported by AASERT funding to the MURI program entitled: "Advanced Magnetic Materials for Aircraft Power Applications" (F49620-96-1-0454). This instrument has been used to measure magnetic domain patterns in Fe-Si and NiMnGa alloys. It has been integrated with a laboratory electromagnet and an automated computer control program. It is currently being used in the thesis project of Mark Storch to measure components of the magnetostriction tensor for FeCo alloys.

20010430 085

15. SUBJECT TE	KMS					
16. SECURITY CLASSIFICATION OF:			17. LIMITATION OF ABSTRACT	18. NUMBER OF PAGES	19a. NAME OF RESPONSIBLE PERSON	
a. REPORT	b. ABSTRACT	c. THIS PAGE	_	.2	19b. TELEPHONE NUMBER (include area code)	
					Standard Form 298 (Rev. 8-98)	

Final Report
P.I. Michael E. McHenry
Dept. of Materials Science and Engineering,
Carnegie Mellon University,
5000 Forbes Avenue,
Pittsburgh, PA 15213-3890

Award Number: F49620-98-1-0185

<u>Title: Research Instrumentation for Investigating Advanced Magnetic Materials for Aircraft Power Applications</u>

2. Technical Objective

This equipment proposal provided funds for a laser speckle interferometer to be used in optical measurements of magnetostrictive strains. Magnetostriction is a significant source of magnetic anisotropy in FeCo alloys. These are key alloys used in the rotor assembly in the integrated power unit of the More Electric Aircraft (MEA). The goals of the MEA include operation of aircraft engines at elevated temperatures. Little is known about high temperature magnetostrictive response. The original research has been aimed at developing new spatially resolved laser interferometric techniques for magnetostriction measurements in FeCo alloys.

3/4. Status of Effort; Accomplishments

A laser speckle interferometer has been purchased with DURIP funds (F49620-98-1-0185) and supported by AASERT funding to the MURI program entitled: "Advanced Magnetic Materials for Aircraft Power Applications" (F49620-96-1-0454). The interferometer was supplied by Applied Optical Systems, at a cost of \$115 K (reflecting a substantial, \$30 K, university discount). This equipment has been installed and implemented in MSE facilities at CMU. The interferometer has been successfully coupled with an existing laboratory electromagnet and an oven assembly with an optical window to study magnetostriction at elevated temperatures. This technique has open up the possibility of new investigations of other important magnetostrictive materials, as well, such as Terfenol, which are of interest to the Navy. It is being used for the study of magnetostriction in FeCo Hiperco alloys.

Magnetostriction is defined as the change in shape of a material upon the application of a magnetic field. In most alloys this is a small effect, generating strain on the order of parts per million, and for most calculations can be safely neglected. However, for premiere soft magnetic materials such as equiatomic iron cobalt alloys, other sources of losses have been minimized to the point that magnetostrictive losses may become significant. Due to the small size of the effect, magnetostriction can be difficult to measure. Typically, strain gauges, with their associated problems, were the

measurement technique of choice. More recently, other techniques have been developed, but all of them are simply extensions or variations on the linear strain measurement provided by the strain gauge technique. We have used electronic speckle pattern interferometry to measure the local displacement field of a sample resulting from the application of a known field. Knowing the local displacement field it is possible to calculate the local strain tensor and possible to calculate the components of the magnetostrictive tensor from the local strain tensor.

This interferometer can be used to measure local magnetostrictive strains with unparalled spatial resolution. With an appropriately developed optical system the extraordinary possibilities for high spatial resolution can be realized (with such an optical system this device can also be used for magnetic domain imaging). Implementation involved fixing a hardware synchronization problem involving the CCD element and interfacing with a controlling computer. Software has been developed (written in Mathematica^{@TM}) that uses these displacements to calculate local strain tensors and an overall magnetostrictive tensor. Mark Storch (with input from Marc DeGraef) has completed a data analysis code for the study of magnetostriction by laser speckle interferometry. This program is currently in the process of being debugged.

Using the electronic speckle pattern interferometer, we have observes what appear to be domain patterns in both Fe-Si alloys as well as NiMnGa alloys. The results for NiMnGa were corroborated with Nomorski imaging on an optical microscope as part of an undergraduate research project. We have also made measurements of the magnetostrictive strains resulting from the application of a magnetic field. Currently we are dealing with the accurate measurement of magnetostriction in equiatomic FeCo alloys (in the thesis research of Mark Storch) with plans to make measurements of pure iron as well. In the case of FeCo, the observations are of the correct order of magnitude and we are working to perfect the experimental technique so as to be able to extract magnetostrictive tensor values.

5. Personnel Supported

None with the funds provided from this equipment grant. M. Storch has been funded with AASERT funding to work on the implementation of this piece of equipment.

6. Publications

Measurement of Magnetostrictive Tensor Components using Electronic Speckle Pattern Interferometry (ESPI), M. L. Storch, A. D. Rollett, M. E. McHenry; 2000 Intermag Meeting – November, 1999 San Jose, to appear in IEEE Transactions on Magnetics.

7. Interactions/Transitions

The laser speckle interferometer has been used in the CMU Materials Science and Engineering senior project research of Robert Barry entitled "Magnetic Characterization of Ni₂MnGa(Al)" and supervised by Marc De Graef.

8. New Discoveries

None

9. Honors/Awards None

10. Summary

A laser speckle interferometer has been purchased with DURIP funds (F49620-98-1-0185) and supported by AASERT funding to the MURI program entitled: "Advanced Magnetic Materials for Aircraft Power Applications" (F49620-96-1-0454). This instrument has been used to measure magnetic domain patterns in Fe-Si and NiMnGa alloys. It has been integrated with a laboratory electromagnet and an automated computer control program. It is currently being used in the thesis project of Mark Storch to measure components of the magnetostriction tensor for FeCo alloys.